

# EC Declaration of Conformity

DoC No: 05091401

We:

System Sensor  
3825 Ohio Avenue  
St. Charles, Illinois 60174  
Telephone: 630-377-6580  
Fax: 630-377-7245  
Website: [www.systemsensor.com](http://www.systemsensor.com)

System Sensor Europe  
15-19 Trescott Road  
Smallwood, Redditch  
Worcestershire, B98 7AH UK  
Telephone: +44 (0) 1527 406700  
Fax: +44 (0) 1527 406699

Declare, under our sole responsibility, that the product:

System Sensor Water Flow Detectors

To which this declaration relates, is in conformity with the following directives, standards and/or other normative documents:

EMC - Electromagnetic Compatibility 89/336/EEC

EN 50130-4:1995 A1: 1998 (Immunity)

EN 61000-6-3:2001 (Emissions)

Mechanical switch not likely to cause, or be affected by EMC disturbance.

EMC assessment conducted by: System Sensor

LVD - Low Voltage Equipment 73/23/EEC

EN 60335-1:2001- Electrical Safety

LVD assessment conducted by: System Sensor

(See TRF 040601001)

CPD - Construction Product Directive 89/106/EEC

Amended by Directive 93/68/EEC

As certified by VDS Schadenverhütung, Amsterdamer Str. 172-174, 50735 Koln

And, has been assigned the following EC Certificate of Conformity:

<u>Model Number</u>	<u>Certificate Number</u>
WFD20E, WFD25E, WFD30-2E, WFD40E, WFD60E, WFD80E	0786-CPD-40151

Also, complies with:

EN 12259-5:2002 – Fixed Firefighting Systems – Components for Sprinkler and Water Spray Systems – Water Flow Detectors.

I, the undersigned, hereby declare that the equipment specified above conforms to the listed directives and standards.

Place of Issue: St. Charles, Illinois

Date: September 14, 2005

CE Mark Affixed: 05



Brian Langkan  
Regulatory Compliance Engineer  
630-377-6674 x1236  
brian.langkan@systemsensor.com

